

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	16.0 cd per klm.
(Luminaire orientation as tested.)	-2.0 degrees vertical
	20.0 degrees horizontal

Beam Spread	At 10% of Imax	129.2V x 168.0H
	At 50% of Imax	101.7V x 152.3H
	At 90% of Imax	82.8V x 144.8H

Beam Flux	Total	14.6 lumens per klm.
	To 10% of Imax	12.6 lumens per klm.
	To 50% of Imax	3.7 lumens per klm.
	To 90% of Imax	0.4 lumens per klm.

Upward LOR	0.0 %
Downward LOR	1.5 %


Luminaire Efficiency (Light Output Ratio)	1.5 %
---	-------

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 06 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 96GRFLED070/T2	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



DATA OF LAMP		PHOTOMETRIC DATA	
MODEL	96GRFLED070/T2	Imax (cd)	46.15
NOMINAL POWER(W)	7	AVAILABILITY (%)	1.3
RATED VOLTAGE (V)	230	Avai. FLUX(lm)	36.27
NOMINAL FLUX(lm)	412	LOR(%)	1.5
LAMPS INSIDE	7	TOTAL FLUX(lm)	42.01
TEST VOLTAGE (V)	230	θ @50% (H,V)	152,102DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM															UNIT:lm			Φ t	Φ a
	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.07	0.00
90	0.00	0.00	0.01	0.01	0.02	0.02	0.02	0.01	0.00	0.01	0.01	0.02	0.03	0.02	0.01	0.01	0.00	0.00	0.20	0.00
80	0.00	0.00	0.01	0.03	0.05	0.05	0.04	0.04	0.02	0.03	0.05	0.05	0.06	0.05	0.03	0.01	0.00	0.00	0.54	0.00
70	0.00	0.01	0.02	0.05	0.08	0.08	0.08	0.08	0.06	0.05	0.09	0.10	0.10	0.08	0.06	0.02	0.01	0.00	0.96	0.04
60	0.00	0.01	0.04	0.07	0.11	0.12	0.15	0.14	0.08	0.12	0.16	0.16	0.15	0.09	0.07	0.04	0.01	0.00	1.53	0.92
50	0.00	0.01	0.05	0.09	0.13	0.17	0.28	0.33	0.10	0.18	0.26	0.32	0.20	0.12	0.09	0.05	0.01	0.00	2.40	2.15
40	0.00	0.02	0.05	0.11	0.17	0.28	0.47	0.46	0.21	0.45	0.31	0.45	0.31	0.15	0.11	0.06	0.02	0.00	3.60	3.47
30	0.00	0.02	0.06	0.12	0.22	0.41	0.54	0.84	0.43	0.51	0.64	0.56	0.45	0.23	0.13	0.07	0.02	0.00	5.24	5.15
20	0.00	0.02	0.06	0.14	0.29	0.51	0.69	1.22	0.54	0.38	1.04	0.78	0.60	0.32	0.15	0.07	0.02	0.00	6.83	6.71
10	0.00	0.02	0.06	0.15	0.29	0.50	0.67	1.02	0.44	0.44	1.18	0.73	0.57	0.31	0.15	0.07	0.02	0.00	6.62	6.50
0	0.00	0.02	0.06	0.14	0.21	0.37	0.47	0.58	0.51	0.43	0.82	0.57	0.45	0.24	0.12	0.06	0.02	0.00	5.08	4.98
-10	0.00	0.01	0.06	0.11	0.15	0.26	0.40	0.28	0.39	0.20	0.48	0.50	0.32	0.18	0.11	0.05	0.01	0.00	3.50	3.36
-20	0.00	0.01	0.05	0.08	0.12	0.19	0.26	0.23	0.16	0.10	0.34	0.32	0.22	0.14	0.09	0.04	0.01	0.00	2.35	2.08
-30	0.00	0.01	0.03	0.07	0.10	0.14	0.15	0.15	0.11	0.09	0.15	0.19	0.14	0.11	0.07	0.03	0.01	0.00	1.53	0.89
-40	0.00	0.01	0.02	0.05	0.07	0.08	0.10	0.09	0.06	0.06	0.08	0.07	0.07	0.08	0.05	0.02	0.01	0.00	0.90	0.00
-50	0.00	0.00	0.01	0.03	0.04	0.05	0.05	0.04	0.02	0.02	0.03	0.03	0.04	0.04	0.02	0.01	0.00	0.00	0.44	0.00
-60	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.01	0.00	0.00	0.01	0.01	0.02	0.01	0.01	0.00	0.00	0.00	0.15	0.00
-70	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.06	0.00
-80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HORIZONTAL (DEG)																				
Φ t	0.01	0.17	0.60	1.27	2.07	3.26	4.38	5.50	3.14	3.08	5.65	4.89	3.74	2.19	1.28	0.61	0.17	0.01	42	---
Φ a	0.00	0.00	0.18	0.91	1.70	2.91	4.02	5.13	2.63	2.56	5.29	4.59	3.41	1.78	0.94	0.22	0.00	0.00	---	36

one-half-peak spread: U:5.7,D:6.1 , L:41.2,R:41.3


NEMA Beam Type: Type 7 x 6 (H x V)

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature:25.3°C
Operators:
Test Date:06 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME: 96GRFLED070/T2	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature:25.3°C
Operators:
Test Date:06 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME: 96GRFLED070/T2	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 06 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

Planar Illuminance Curve




C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 06 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

AAI Figure

NAME: 96GRFLED070/T2	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:



Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 06 October 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRFLED070/T2	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:

Table--1

UNIT: cd

H(DEC) V(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.06	0.06	0.09	0.12	0.15	0.18	0.22	0.24	0.26	0.30	0.31	0.32	0.27	0.20	0.12	0.06	0.02	0.00	0.00
-85	0.06	0.07	0.12	0.15	0.20	0.21	0.25	0.25	0.28	0.28	0.30	0.27	0.26	0.18	0.14	0.07	0.04	0.00	0.00
-80	0.06	0.09	0.16	0.18	0.26	0.28	0.33	0.35	0.38	0.35	0.39	0.39	0.38	0.24	0.18	0.14	0.09	0.01	0.02
-75	0.06	0.10	0.19	0.24	0.33	0.38	0.46	0.56	0.60	0.66	0.69	0.70	0.75	0.55	0.40	0.34	0.26	0.10	0.09
-70	0.06	0.12	0.23	0.30	0.42	0.54	0.71	0.97	1.12	1.11	1.20	1.37	1.34	0.99	0.81	0.75	0.66	0.30	0.14
-65	0.06	0.13	0.26	0.37	0.56	0.77	1.12	1.52	1.82	1.99	2.03	1.93	1.84	1.67	1.43	1.38	1.24	0.63	0.30
-60	0.06	0.15	0.29	0.45	0.77	1.07	1.59	2.20	2.75	2.78	2.66	2.51	2.26	2.48	2.53	2.26	2.00	1.41	0.62
-55	0.06	0.17	0.34	0.61	1.05	1.47	2.14	2.77	3.30	3.38	3.25	3.33	3.28	3.75	3.16	3.03	2.61	1.92	0.79
-50	0.06	0.18	0.38	0.76	1.38	1.93	2.59	3.29	3.73	3.98	3.81	4.34	4.73	4.10	4.18	3.88	3.08	2.43	2.00
-45	0.06	0.20	0.41	0.94	1.78	2.54	3.01	3.73	4.35	4.13	5.04	5.59	5.69	5.01	5.39	5.05	4.16	3.91	3.35
-40	0.06	0.21	0.46	1.13	2.13	3.11	3.41	4.22	4.47	5.15	5.99	6.56	6.27	6.97	7.27	6.58	6.12	4.39	2.08
-35	0.06	0.23	0.53	1.31	2.51	3.72	4.16	4.73	5.12	5.70	6.76	7.66	8.02	9.74	9.91	8.98	5.34	4.57	3.70
-30	0.06	0.24	0.60	1.49	2.85	4.14	4.90	5.18	5.63	5.88	7.49	8.79	10.7	12.7	12.7	6.45	6.34	8.94	7.71
-25	0.06	0.25	0.67	1.65	3.20	4.49	5.67	6.13	6.19	6.45	8.49	10.1	13.5	16.4	10.8	7.84	11.1	14.9	9.76
-20	0.06	0.26	0.73	1.79	3.49	4.74	6.30	7.12	7.13	7.40	10.0	11.8	16.8	15.9	12.4	12.1	17.7	15.9	12.3
-15	0.06	0.27	0.78	1.91	3.71	4.78	6.42	8.26	8.91	8.98	12.3	13.8	17.8	16.7	17.3	18.9	20.8	17.5	12.9
-10	0.06	0.27	0.82	2.01	3.86	4.76	6.23	8.62	10.4	11.4	15.5	17.2	17.1	19.8	23.9	30.1	22.8	18.7	7.80
-5	0.06	0.28	0.86	2.07	3.93	4.75	6.17	8.75	10.9	12.8	18.5	21.7	18.5	24.4	30.8	37.1	28.7	13.4	3.58
0	0.06	0.28	0.88	2.11	3.93	4.68	6.14	8.65	11.2	13.6	20.1	24.6	20.4	26.6	38.5	41.6	40.9	7.97	3.57
5	0.06	0.28	0.88	2.09	3.72	4.49	5.95	8.34	10.2	12.8	18.5	23.3	17.6	22.6	39.5	42.3	40.4	17.2	4.05
10	0.06	0.28	0.87	2.04	3.49	4.27	5.69	7.84	8.94	11.4	16.2	20.9	14.2	20.6	32.9	41.0	31.0	20.7	7.40
15	0.06	0.28	0.85	1.96	3.31	4.15	5.39	7.27	8.06	9.92	13.9	18.0	15.0	18.0	28.1	29.9	23.4	11.8	9.72
20	0.06	0.28	0.82	1.84	3.25	4.02	5.09	6.73	7.50	8.68	11.3	14.6	16.1	17.5	22.6	21.3	14.2	8.25	13.3
25	0.06	0.27	0.78	1.70	3.20	3.90	4.81	6.10	7.14	7.51	8.73	11.2	12.9	18.6	19.3	15.7	8.38	4.65	12.8
30	0.06	0.27	0.73	1.53	3.07	3.68	4.54	5.54	6.61	6.80	6.78	8.30	10.6	13.7	18.9	14.1	4.96	2.64	9.23
35	0.06	0.26	0.67	1.35	2.68	3.41	4.26	5.20	5.86	6.41	5.78	6.61	8.69	9.28	12.2	13.1	7.44	2.30	4.05
40	0.06	0.25	0.60	1.19	2.25	3.22	3.80	4.56	5.08	5.85	5.65	5.70	6.50	6.68	7.53	7.24	4.85	1.81	2.38
45	0.06	0.24	0.53	1.02	1.87	3.02	3.30	3.87	4.73	4.88	5.32	5.15	4.92	5.55	5.21	4.59	3.37	2.50	2.99
50	0.06	0.22	0.47	0.85	1.48	2.38	2.91	3.30	3.97	4.41	4.50	3.94	3.55	4.08	4.32	3.18	2.88	2.21	2.12
55	0.06	0.21	0.39	0.72	1.17	1.79	2.41	2.85	3.32	3.64	3.80	2.98	2.40	2.71	2.94	2.88	2.36	2.02	1.03
60	0.06	0.19	0.32	0.57	0.86	1.29	1.74	2.31	2.77	2.99	2.86	2.29	2.09	1.82	1.88	2.05	2.08	1.32	0.59
65	0.06	0.18	0.28	0.46	0.65	0.88	1.22	1.67	2.11	2.22	2.10	1.94	1.75	1.58	1.29	1.18	1.16	0.77	0.38
70	0.06	0.17	0.24	0.35	0.48	0.63	0.81	1.10	1.35	1.43	1.27	1.30	1.46	1.33	0.81	0.56	0.45	0.24	0.14
75	0.06	0.15	0.20	0.30	0.35	0.46	0.53	0.70	0.83	0.80	0.75	0.78	0.81	0.75	0.41	0.27	0.15	0.11	0.08
80	0.06	0.14	0.17	0.25	0.27	0.34	0.36	0.44	0.46	0.44	0.41	0.42	0.43	0.33	0.16	0.11	0.03	0.04	0.01
85	0.06	0.12	0.14	0.21	0.22	0.28	0.27	0.33	0.33	0.34	0.30	0.27	0.21	0.18	0.10	0.07	0.00	0.00	0.00
90	0.06	0.11	0.11	0.17	0.19	0.24	0.26	0.29	0.32	0.35	0.36	0.27	0.24	0.16	0.11	0.05	0.00	0.00	0.00

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature:25.3°C
Operators:
Test Date:06 October 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRFLED070/T2	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F120 x 110	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: round	Shielding Angle:

Table--2

UNIT: cd

H(DEC) V(DEC)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.00	0.00	0.05	0.11	0.19	0.22	0.27	0.29	0.28	0.26	0.23	0.21	0.18	0.16	0.12	0.11	0.07	0.06	
-85	0.00	0.02	0.05	0.12	0.16	0.21	0.24	0.29	0.28	0.30	0.26	0.26	0.21	0.20	0.15	0.14	0.08	0.06	
-80	0.00	0.04	0.07	0.16	0.23	0.31	0.30	0.33	0.35	0.39	0.36	0.34	0.28	0.26	0.19	0.17	0.10	0.06	
-75	0.06	0.12	0.20	0.32	0.53	0.61	0.60	0.61	0.63	0.62	0.53	0.44	0.36	0.32	0.24	0.20	0.11	0.06	
-70	0.16	0.32	0.39	0.62	1.00	1.05	0.99	1.07	1.20	1.08	0.87	0.61	0.49	0.40	0.30	0.24	0.13	0.06	
-65	0.52	0.88	0.92	1.01	1.27	1.39	1.57	1.86	1.98	1.74	1.37	1.05	0.69	0.52	0.37	0.27	0.14	0.06	
-60	1.34	1.83	1.74	1.49	1.47	1.68	1.94	2.85	2.86	2.54	2.02	1.48	1.09	0.69	0.44	0.30	0.16	0.06	
-55	1.96	2.60	2.86	2.49	2.48	1.92	2.62	3.72	3.64	3.20	2.72	2.05	1.48	0.95	0.58	0.35	0.18	0.06	
-50	2.58	3.22	3.51	4.54	4.77	4.10	3.84	4.04	4.41	3.95	3.34	2.67	1.92	1.21	0.72	0.39	0.20	0.06	
-45	3.16	3.79	4.79	6.43	7.38	6.11	5.62	5.38	4.47	4.83	3.94	3.23	2.42	1.54	0.87	0.43	0.21	0.06	
-40	2.08	4.28	7.59	9.44	9.09	8.29	6.98	6.37	5.85	4.76	4.65	3.72	2.85	1.86	1.02	0.47	0.23	0.06	
-35	2.39	7.05	12.5	13.4	10.7	10.7	8.31	7.11	6.78	5.60	5.15	4.10	3.22	2.23	1.17	0.54	0.24	0.06	
-30	2.66	5.99	16.0	19.1	14.3	12.4	10.3	8.04	7.40	6.62	5.27	4.43	3.51	2.59	1.36	0.61	0.26	0.06	
-25	4.68	8.24	15.7	22.1	19.0	14.0	13.1	9.58	8.30	7.32	6.09	4.72	3.74	2.89	1.56	0.67	0.27	0.06	
-20	8.51	14.8	20.6	21.6	20.6	16.3	16.5	11.8	9.36	7.85	6.78	4.86	3.93	3.15	1.73	0.72	0.28	0.06	
-15	11.8	24.3	28.9	27.5	18.6	18.7	19.9	14.4	10.7	8.49	7.23	5.20	4.21	3.38	1.89	0.76	0.28	0.06	
-10	17.4	28.7	41.0	34.1	21.1	16.9	23.5	17.3	12.0	9.25	7.84	5.61	4.50	3.63	2.02	0.79	0.29	0.06	
-5	13.4	34.1	40.9	42.2	24.1	17.3	27.2	20.1	13.7	10.3	8.40	6.19	4.95	3.89	2.13	0.81	0.29	0.06	
0	5.61	36.6	40.2	44.8	28.2	20.7	29.4	22.3	14.9	12.0	8.84	6.81	5.39	4.12	2.20	0.82	0.30	0.06	
5	9.49	27.9	37.0	36.2	29.5	21.2	27.2	21.4	14.5	11.4	8.68	6.69	5.43	4.11	2.17	0.81	0.30	0.06	
10	16.9	22.6	31.1	27.7	24.9	19.7	21.9	18.3	12.7	10.3	8.27	6.50	5.40	4.04	2.11	0.80	0.29	0.06	
15	18.0	19.5	22.8	20.6	19.9	20.5	17.1	14.0	9.91	8.70	7.61	6.20	5.19	3.89	2.02	0.78	0.29	0.06	
20	17.8	19.7	13.6	14.9	16.8	21.2	14.5	11.1	8.03	7.14	6.66	6.08	4.88	3.66	1.91	0.74	0.28	0.06	
25	16.6	12.8	8.77	11.3	18.7	16.5	12.1	8.88	6.81	6.37	5.98	5.74	4.51	3.38	1.76	0.69	0.27	0.06	
30	11.9	7.54	6.32	13.2	15.3	12.7	9.67	7.42	6.00	5.79	5.29	5.18	4.22	3.04	1.58	0.64	0.26	0.06	
35	5.35	5.56	10.1	12.6	11.8	9.26	8.03	6.52	5.46	5.14	4.85	4.58	3.88	2.64	1.38	0.57	0.25	0.06	
40	4.38	7.50	8.30	8.51	8.01	7.15	7.19	5.89	4.79	4.54	4.47	3.93	3.37	2.22	1.16	0.50	0.24	0.06	
45	4.55	4.89	5.42	5.70	5.44	6.71	6.38	5.13	3.95	4.48	4.04	3.63	2.81	1.87	0.92	0.45	0.22	0.06	
50	2.40	3.13	3.76	4.24	4.52	5.80	5.22	4.11	4.05	3.88	3.75	3.13	2.29	1.48	0.74	0.40	0.21	0.06	
55	1.51	2.56	3.12	3.15	3.89	4.21	4.34	3.78	3.61	3.49	3.35	2.55	1.80	1.13	0.62	0.34	0.19	0.06	
60	1.58	2.21	2.38	2.50	2.70	2.83	3.29	3.22	3.25	3.17	2.64	1.99	1.32	0.82	0.48	0.29	0.17	0.06	
65	0.74	1.57	1.67	1.61	1.80	2.19	2.54	2.64	2.51	2.29	1.89	1.40	0.93	0.61	0.41	0.25	0.15	0.06	
70	0.42	0.83	0.92	0.94	1.21	1.87	2.00	1.68	1.55	1.44	1.19	0.84	0.63	0.44	0.33	0.21	0.13	0.06	
75	0.17	0.28	0.44	0.43	0.68	1.02	0.98	0.94	0.85	0.79	0.67	0.50	0.44	0.32	0.27	0.17	0.11	0.06	
80	0.05	0.08	0.18	0.22	0.34	0.49	0.52	0.48	0.46	0.41	0.41	0.34	0.32	0.24	0.21	0.14	0.09	0.06	
85	0.02	0.03	0.11	0.15	0.23	0.28	0.33	0.32	0.32	0.29	0.30	0.24	0.24	0.18	0.16	0.11	0.07	0.06	
90	0.00	0.03	0.09	0.15	0.22	0.28	0.31	0.32	0.28	0.27	0.24	0.21	0.18	0.14	0.11	0.08	0.05	0.06	

C Range: 0 - 360DEG

C Interval: 5.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:06 October 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks: